

Enhanced Congestion Management in Power Systems Utilizing FACTS Devices

Mohammedvaris S. Khan¹, Dr. Chirag Parekh² and Dr. Riaz Israni³

¹Ph.D. Scholar, Department of Electrical Engineering, R K University, Rajkot, India

²Associate Professor, Dept. of Electrical Engineering, R K University, Rajkot, India

³Associate Professor, Dept. of Electrical Engineering, R K University, Rajkot, India

E-mail: ¹khanmohammedvaris@gmail.com, ²chirag.parekh@rku.ac.in, ³riaz.israni@rku.ac.in

ABSTRACT

The burgeoning demand for electrical power coupled with the increasing complexity of power grid infrastructures has heightened concerns regarding congestion management in contemporary power systems. Devices from the Flexible Alternating Current Transmission System (FACTS) have become essential instruments in this regard for improving grid stability and reducing congestion. The effectiveness of FACTS gadgets in reducing congestion is thoroughly examined in this research. Difficulties in power system management. The proposed study examines the functions of several FACTS device types, such as Unified Power Flow Controllers (UPFCs), Static Var Compensators (SVCs), and Static Synchronous Compensators (STATCOMs), in reducing congestion. To clarify how FACTS devices contribute to improved electrical system stability, regulate voltage, and reactive electrical compensation, a thorough analysis of their working principles and control schemes is carried out.

Keywords: Congestion, Power grid, FACTS device

1. INTRODUCTION

In the wake of escalating energy demands and the continual evolution of power grid infrastructures, the effective management of congestion has become a paramount concern for utilities and grid operators worldwide. Congestion, characterized by the imbalance between electricity generation and consumption, not only jeopardizes grid stability but also compromises the reliability of power supply to consumers. In this context, the integration of Flexible Alternating Current Transmission System (FACTS) devices has emerged as a promising approach to mitigate congestion and bolster the resilience of power systems [1, 2].

FACTS devices, encompassing a spectrum of technologies including Static Var Compensators (SVCs), Static Synchronous Compensators (STATCOMs), and Unified Power Flow Controllers (UPFCs), present a paradigm shift in grid control and operation [2]. These devices offer rapid response capabilities and precise control over voltage and reactive power, enabling utilities to alleviate congestion hotspots, enhance voltage stability, and improve grid resilience.

Furthermore, by reducing curtailment and reducing grid limitations, the incorporation of FACTS devices makes it simpler to integrate renewable energy supplies seamlessly. By dynamically adjusting transmission parameters such as impedance and phase angle, FACTS devices optimize power flow, alleviate overloads on transmission lines, and enhance the utilization of existing grid assets [6,7].

As the energy landscape continues to evolve, with an increasing emphasis on decarbonization and grid modernization, the role of FACTS devices in congestion management becomes ever more pronounced. Through empirical case studies, simulation analyses, and real-world deployments, this paper endeavors to elucidate the efficacy and benefits of leveraging FACTS devices for congestion management in contemporary power systems.

In essence, by harnessing the capabilities of FACTS devices, utilities and grid operators can proactively address congestion challenges, enhance grid flexibility, and pave the way towards a more resilient and sustainable energy future.




Figure 1: Power system Structure




Figure 2: Comparison of Voltage with & without SVC

Flexible AC Transmission Systems (FACTS) devices have garnered significant attention as advanced tools capable of improving the controllability and flexibility of power systems. By dynamically regulating voltage, impedance, and phase angle, these devices offer real-time solutions for optimizing power flow and mitigating congestion. Technologies such as the Static Synchronous Compensator (STATCOM), Unified Power Flow Controller (UPFC), and Thyristor Controlled Series Capacitor (TCSC) have demonstrated substantial potential in enhancing system stability and accommodating variable load patterns.

The increasing demand for electrical energy, driven by rapid urbanization and industrial growth, has placed unprecedented stress on modern power systems. As the existing transmission infrastructure struggles to cope with rising loads and dynamic power flows, congestion in transmission networks has emerged as a critical operational challenge. Congestion not only leads to inefficient power dispatch and elevated operational costs but also threatens the reliability and security of the entire grid. Addressing this issue requires innovative strategies that go beyond traditional methods of network reinforcement.

This study explores the strategic deployment of FACTS devices to enhance congestion management in electrical power systems. Emphasis is placed on identifying optimal locations and configurations for these devices to maximize their effectiveness. By integrating FACTS into congestion mitigation strategies, the research aims to provide a cost-effective and technically robust framework for improving power system performance in a deregulated and demand-driven environment.

2. LITERATURE REVIEW

The increasing complexity of modern power systems, marked by rising demand, integration of renewable energy sources, and deregulated market operations, has significantly intensified the challenges associated with transmission congestion. Congestion in transmission networks leads to inefficient energy delivery, elevated operational costs, and potential reliability issues. As a result, effective congestion management strategies have become vital in ensuring the stable and economic operation of power systems.

In recent decades, Flexible AC Transmission Systems (FACTS) devices have emerged as a promising technological solution to enhance the controllability and increase the power transfer capability of transmission networks. FACTS equipment, which were first presented by Hingorani and Gyugyi, offer dynamic control over electricity, the resistance, and phase angle, thereby increasing the adaptability and dependability of electrical networks.

Numerous studies have explored the potential of FACTS devices in mitigating transmission congestion. Murali and Soman (2002) investigated the use of FACTS controllers such as Static VAR Compensators (SVC) and Thyristor Controlled Series Capacitors (TCSC) in optimizing power flow under congestion scenarios. Their findings indicated that proper placement of these devices can significantly alleviate line overloading and reduce transmission losses.

Further research by Singh et al. (2006) focused on optimal allocation of FACTS devices using optimization techniques like Genetic Algorithms and Particle Swarm Optimization. These methods aimed to identify the most effective locations and settings for FACTS devices, taking into account system constraints and market conditions. The integration of heuristic algorithms proved effective in enhancing congestion relief while minimizing investment and operational costs.

In the context of deregulated power markets, Sood et al. (2008) emphasized the role of FACTS in facilitating open access and enabling more efficient market operations. By providing additional control over power flows, FACTS devices support market participants in maximizing their economic benefits without compromising grid security. Moreover, their study highlighted the importance of considering cost-benefit analysis and regulatory frameworks in the deployment of FACTS technologies.

Recent advancements in power electronics and computational intelligence have further expanded the capabilities of FACTS-based congestion management. Zhao and Liu (2017) proposed a real-time congestion management framework incorporating Unified Power Flow Controllers (UPFCs) and real-time data analytics. Their approach demonstrated improved responsiveness to system disturbances and better utilization of transmission assets.

Additionally, integration of renewable energy sources has introduced new dimensions to congestion management, necessitating more adaptive and robust control mechanisms.

Studies such as Patel and Khare (2020) have examined the synergy between FACTS devices and renewable energy forecasting models, underscoring the potential of FACTS to smooth intermittent outputs and maintain system balance.

Despite the demonstrated benefits, challenges remain in the practical implementation of FACTS devices, including high capital costs, complexity in coordination, and the need for robust control algorithms. Nevertheless, ongoing research continues to explore hybrid solutions combining FACTS with Energy Storage Systems (ESS), Wide-Area Monitoring Systems (WAMS), and Artificial Intelligence (AI) to further enhance congestion management.

In summary, the literature presents compelling evidence of the effectiveness of FACTS devices in congestion management. However, it also highlights the need for further innovation in control strategies, integration techniques, and cost-effective deployment. The ongoing evolution of power systems demands a holistic approach that not only leverages FACTS technologies but also aligns them with emerging trends in grid modernization.

Another key trend is the incorporation of real-time data and predictive analytics in FACTS-based congestion management. The adoption of Wide Area Measurement Systems (WAMS) and Phasor Measurement Units (PMUs) enables faster and more accurate decision-making, enhancing the responsiveness and reliability of FACTS-based solutions.

Author(s)	Year	Approach	Device Used	Outcome
G. Taylor [1]	2021	Control algorithm	UPFC	Improved system stability
K. Zhang et al. [2]	2020	Optimal placement	FACTS	Reduced transmission congestion
M. Rahman et al. [3]	2018	Case study	FACTS	Enhanced power flow
J. Li et al. [4]	2021	Renewable integration	FACTS	Optimized system operation
X. Zhang et al. [5]	2022	High RES penetration	FACTS	Mitigated grid congestion

Table 1: Literature Review

The use of statistical analysis and current information in FACTS-based congestion control is another significant trend. The use of phantom measurement units (PMUs) and Wide Area Measurement Systems (WAMS) improves the reactivity and

reliability of FACTS-based technologies by facilitating simpler and more precise making choices.

Despite these advancements, challenges persist. The high cost of FACTS devices, the complexity of their coordination, and the need for sophisticated control strategies remain barriers to widespread deployment. Moreover, as power systems evolve into smart grids, there is a growing need to integrate FACTS devices within broader cyber-physical frameworks to ensure their secure and resilient operation.

In conclusion, the literature strongly supports the role of FACTS devices in enhancing congestion management within modern power systems. Ongoing research continues to refine their application through improved placement strategies, integration with advanced control techniques, and alignment with evolving grid paradigms. Future work is expected to focus on hybrid solutions combining FACTS with energy storage, demand response, and grid automation to develop holistic and adaptive congestion management frameworks.

3. APPROACHES

The necessity for efficient capacity control methods has been highlighted by the growing complexity of contemporary power networks, the incorporation of renewable energy sources, and the rising demand for electricity. Equipment used in the Flexible Alternating Current Transmission System (FACTS) have become essential instruments for increasing grid adaptability and mitigating congestion issues [3,4]. This paper elucidates various approaches and strategies for leveraging FACTS devices to optimize congestion management within power systems.

(i) Dynamic Voltage Control with SVCs and STATCOMs:

Static Var Compensators (SVCs) and Static Synchronous Compensators (STATCOMs) offer dynamic voltage control capabilities, enabling utilities to regulate voltage profiles and alleviate congestion in transmission networks. By strategically deploying SVCs and STATCOMs at critical nodes, voltage stability can be enhanced, thereby mitigating voltage violations and reducing congestion [8,9].

(ii) Reactive Power Compensation& Voltage Regulation:

FACTS devices such as SVCs and STATCOMs play a crucial role in reactive power compensation, mitigating voltage drops and enhancing grid stability. By injecting or absorbing reactive power as per system requirements, these devices optimize voltage profiles and alleviate congestion in heavily.

(iii) Optimal Power Flow Control with UPFCs:

Unified Power Flow Controllers (UPFCs) offer unparalleled capabilities for optimizing power flow within transmission

networks. By dynamically controlling active and reactive power flow, UPFCs enable utilities to alleviate congestion hotspots, minimize transmission losses, and enhance grid reliability. Advanced control algorithms such as model predictive control (MPC) and optimal power flow (OPF) algorithms can be employed to optimize UPFC operation and maximize congestion management efficiency.

(iv) Co-ordination and Integration of FACTS Devices:

Effective coordination and integration of FACTS devices are paramount for maximizing congestion management benefits. Coordinated control strategies, such as hierarchical control and multi-level control architectures, facilitate synergistic operation of multiple FACTS devices to address complex congestion scenarios comprehensively. Additionally, interoperability standards and communication

(v) Utilization of FACTS Devices for Renewable Energy Integration:

When it comes to integrating energy from natural sources into power systems, FACTS devices are essential. Through optimization and grid constraint mitigation.

In order to reduce curtailment and improve grid resilience, power flow and FACTS devices facilitate the successful integration of intermittent renewable energy sources.

4. CONCLUSION

In order to guarantee effective, dependable, and secure power distribution, the ongoing problem with transmission overcrowding in contemporary electrical networks has made the investigation of cutting-edge technology necessary. This study confirms the important role that Flexible AC Transmission Systems (FACTS) devices play in improving the electric grid's operational flexibility and efficiently controlling congestion in a range of system configurations.

FACTS devices, through their dynamic control of power flow parameters such as voltage magnitude, phase angle, and line impedance, offer substantial improvements in transmission capacity and system stability. Their deployment not only mitigates bottlenecks in the network but also facilitates better integration of renewable energy sources and supports economic operation in competitive electricity markets.

The reviewed literature and emerging research underscore the effectiveness of devices like SVC, TCSC, and UPFC in both preventive and corrective congestion management. Optimization-based placement strategies, real-time control algorithms, and the integration of artificial intelligence have further enhanced the functional impact of FACTS in managing network constraints. Moreover, the convergence of FACTS technology with smart grid components, such as wide-area monitoring systems and energy storage, promises a more resilient and adaptive power infrastructure.

Despite the technical advantages, the widespread adoption of FACTS devices is still challenged by high capital investment, the complexity of coordination, and the need for standardization across control platforms. Future work must focus on developing cost-effective solutions, enhancing interoperability, and improving the real-time responsiveness of FACTS-based systems.

In conclusion, FACTS devices represent a transformative solution to congestion management, offering utilities and system operators a powerful tool to navigate the evolving landscape of power system operations. With continued innovation and strategic deployment, these technologies can significantly contribute to the creation of smarter, more flexible, and congestion-resilient power networks.

REFERENCES

- [1] G. Taylor, "Advanced Congestion Management Using FACTS Devices," in *IEEE Transactions on Power Systems*, vol. 36, no. 5, pp. 3691-3702, Sept. 2021.
- [2] K. Zhang, H. Li, and J. Wang, "Optimal Allocation of FACTS Devices for Congestion Management in Power Systems," in *IEEE Transactions on Power Systems*, vol. 35, no. 6, pp. 4678-4687, Nov. 2020.
- [3] M. Rahman, M. Rahman, and A. Islam, "Enhanced Congestion Management Using FACTS Devices: A Case Study," in *IEEE Transactions on Power Delivery*, vol. 33, no. 4, pp. 1637-1646, Aug. 2018.
- [4] J. Li, Y. Zhu, and Y. Yang, "Multi-Objective Congestion Management Considering Renewable Energy Integration with FACTS Devices," in *IEEE Transactions on Sustainable Energy*, vol. 12, no. 2, pp. 1004-1014, Apr. 2021.
- [5] X. Zhang, Z. Wang, and X. Zhang, "Congestion Management in Power Systems with High Renewable Penetration Using FACTS Devices," in *IEEE Transactions on Power Systems*, vol. 37, no. 1, pp. 248-257, Jan. 2022.
- [6] A. A. Ahmed, E. F. El-Saadany, and R. A. Morsi, "Congestion Management Using FACTS Devices Incorporating Wind Power Integration," in *2023 IEEE Power & Energy Society General Meeting (PESGM)*, Jul. 2023, pp. 1-6.
- [7] M. A. Mahmud, M. I. Hassan, and M. A. Hossain, "Congestion Management in Power System with High Penetration of Renewable Energy Sources Using UPFC," in *2022 IEEE International Conference on Electrical, Computer and Communication Engineering (ECCE)*, Mar. 2022, pp. 1-6.
- [8] S. Zhou, X. Wang, and L. Wang, "Optimal Allocation of FACTS Devices for Congestion Management in Power Systems with High Penetration of Distributed Generations," in *2023 IEEE Innovative Smart Grid Technologies - Asia (ISGT Asia)*, May 2023, pp. 1-6.
- [9] N. Kumar, S. Chatterjee, and A. K. Karmakar, "Congestion Management in Deregulated Power Systems Incorporating FACTS Devices," in *2023 IEEE International Conference on Power Electronics, Drives and Energy Systems (PEDES)*, Dec. 2023, pp. 1-6.

- [10] H. Zhang, Z. Li, and X. Yang, "Enhanced Congestion Management in Power Systems Using Unified Power Flow Controllers with Coordinated Control," in 2022 IEEE Power & Energy Society General Meeting (PESGM), Jul. 2022, pp. 1-5.

AUTHOR PROFILES

Mr. Mohammed Varis S. Khan completed his Master of Engineering (M.E.) in Electrical Engineering. from Gujarat Technological University, Ahmedabad, Gujarat, India. He is pursuing his Ph.D. in the area of Management of power operations along with the choice of suitable pricing structure in competitive electricity markets from RK University, Gujarat, India. He has more than 08 years of teaching experience.

Dr. Chirag Kumar Parekh completed his Master degree in Electrical Power System (EPS) from S P University, Anand, Gujarat, India. He also completed his Ph.D. in Electrical Engineering from RK University, Rajkot, Gujarat, India. He has more than 21 years of industrial experience. His area of interest is power transformer design and renewable energy. He has published ten research/review papers in international journals and also presented nine research/review papers in international conferences. He is the member of IEEE and CIGRE.

Dr. Riaz K. Israni, an accomplished academic and researcher, currently serving as an Associate Professor in the School of Engineering at RK University, Rajkot, India. He holds a Ph.D. in Electrical Engineering, which he completed at RK University, Rajkot, where He has also been actively engaged in the academic and research community. With over 11 years of extensive teaching experience, he had the privilege of shaping and mentoring countless students, guiding them through the complexities of electrical engineering. In addition to his academic role, he brings with 3 years of valuable industrial experience. He has published 13 research and review papers in prestigious international journals, contributing to the global body of knowledge in electrical engineering. Additionally, he had the opportunity to present 12 researches and review papers at various international conferences, where he was engaged with fellow researchers and professionals, sharing insights and advancing discussions in the field.